





mbar

loss, 1

Pressure

Special configuration of side fins

enhanced heat exchange

õ


EVOLUTION: SERIR S5

Serir S5 is NOVA FLORIDA's new range of high-tech radiators that feature numerous technological innovations:

- Innovative geometry of the 5 rows of side fins, developed with thermo-fluid dynamic simulations and climatic chamber tests, resulting in a high heat output with a smaller surface area and hence less weight.
- Presence of rear openings allowing enhanced heat exchange by convection.
- A new cap for the element.
- Ornamental patent, and patent pending for new technical developments.


Heat output Heat output Centre Connection Water Depth Height Length Weight Exponent Coefficient Ø distance ΔT 30K **ΔT 50K** diameters capacity (C) mm (B) mm (D) mm Kg/sect. n K (A) mm inches litres/sect. W/sect. W/sect. 500/100 97 557 G1 1.30 60.1 116.9 500 80 0.31 1.3014 0.7191

Pressure loss Serir S5 500/100



Maximum working pressure: 1600 kPa (16 bar)

Characteristic equation of the model Φ =Km Δ Tn (reference EN 442-1). The thermal efficiency values, expressed at Δ T 50K, comply with EN 442-2 and are certified by the MRT Lab of the Milan Polytechnic, notified body no. 1695.





- The new cap is not welded and hydraulic seal is provided by an **O-ring seal**.
- The new cap is made of **aluminized steel**.
- No welds, so no problems with burrs at the bottom of the radiator.
- All the caps for the models in the Serir S5 range

undergo Aleternum[®] anticorrosion treatment.

2011 BRAND NEW CREATION

- *S5 is lighter than the models in the S3 range, and hence easier to transport and install*;
- S5 has an optimal weight-to-heat output ratio;
- S5 features numerous exclusive technological innovations;
- *S5 has an innovative cap.*



• new technical solution: cap with no welding required



SERIR S5

CE.



Fondital guarantees **Serir S5** for **10 years** from the date of installation against all production defects providing the heating system is conform to the regulations, in compliance with the standards in force and provided the instructions on installation, use and correct maintenance supplied with the product have been observed.